



Jim Doyle, Governor
Mary P. Burke, Secretary

January 22, 2007

VAN HANDEL CONCRETE PRODUCTS
KEN VAN HANDEL
5325 N. BALLARD RD.
APPLETON WI 54913-8941

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: VAN HANDEL CONCRETE PRODUCTS
Product Name: SEPTIC, HOLDING, GREASE INTERCEPTOR OR PUMP
Model Number(s): 1200/800
(50" L.L., 24.92/16.02 GAL/IN., 24" MAX. DEPTH OF BURY, 597 G.P.D. WHEN USED AS A
SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20070053

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code.
This approval is valid until the end of January 2012.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Cast-A-Seal and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Department approved effluent filter designed to be installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

This approval supersedes the approval issued on 04/8/2002 under product file number 20020078. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020078. The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST, Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658; 201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov
SBD-10564-E (N.10/97)